## WATER AND WASTEWATER DESIGN CRITERIA Appendix D – Utility Product Requirements



## **APPENDIX D - Utility Product Requirements**

## **D.1** Introduction

General: The City of Rio Rancho requires that any utility product(s) being used on a Capital or Developer project have a valid ASTM or AWWA specification. If the product(s) do not have an ASTM or AWWA specification associated with them, they will not be approved for use within the City of Rio Rancho. Failure of the contractor/engineer to assure and provide evidence of the valid ASTM or AWWA specification to the City's project manager before installation may require removal of the deficient product(s) and replacement of a product(s) with a valid ASTM or AWWA product at the contractor's/engineer's expense.