

NOTES:

- 1 BEDDING MATERIALS SHALL BE CLASSED AS DEFINED IN ASTM D-2321
- 2 COMPACTION TESTING SHALL BE TAKEN AT SPRINGLINE OF PIPE.
- 3 COMPACTION TESTING SHALL BE TAKEN AT BACKFILL ZONE.
- 4 ALL BACKFILL SHALL BE 95% PER STANDARD MODIFIED PROCTOR.

City of Rio Rancho-Department of Public Infrastructure			
APPROVED BY: DATE:	PIPE BEDDING		R RioRancho
PUBLIC INFRASTR DATE: 7/91 REV.: 2/06	UCTURE DEPARTMENT ENGINEERING DIVISION	STANDARD DRAWING S-4	City of Vision